

2021 Cooling Tower Test Results

RED CELL HCC >200K cfu or Leg > = 10 cfu

CT No	Location	Sampling Date	Sampling Date	Sampling Date	Sampling Date	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Sampli ng	Sampli ng	Sampli ng	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date
		13-Jan	13-Jan	10-Feb	10-Feb	10-Mar	10-Mar	11-Mar	11-Mar	7-Apr	7-Apr	5-May	5-May	2-Jun	2-Jun	30-Jun	30-Jun	13-Jul	13-Jul
		HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg
1	37 - North Ground - Engineering 37	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	-	-	Clr	Clr	-	-
5	37 - Engineering 37 Annex	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
6	36 - Roof Area - Engineering 36	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8	30 - Hargrave Library	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
10	28 - Mathematics Building	-	-	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
21	23 - Chemistry - S-West Roof	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23	23 - Science N - Chem Roof Area	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
26	18 - Zoology West - Roof Area	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
29	17 - Biology - Roof Area	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
37	12 - Law School - Roof Area	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
43	5 - Krongold Centre - Roof Plant Rm	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	-	-	-	-	-	-	-	-
51	11 - Menzies South - 9th Fl. Roof, Unit 1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
54	75 - STRIP 1	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
56	11 - Menzies South - 9th Fl. Roof, Unit 2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
57	35 - Building 35 Roof	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
58	23 - Chemistry Roof E.	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
59	23 - Chemistry Roof E.	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
31/32	13F - Medicine 13F - Roof Plant Room	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
34/ 35	13D - Medicine 13D - Roof Area	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr
46/ 47	68 - Performing Arts Centre - E Roof	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr
49/ 50	25 - Eastern Science L.T. 25	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	-	-	-	-	-	-	-	-
52/ 53	75 - STRIP 1	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
60/ 61	76 - STRIP 2 Roof (#60 to E; #61 to W)	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
62/ 63	86 - Green Chemical Futures	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	-	-	-	-
Location	Sampling Date	Sampling Date	Sampling Date	Sampling Date	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Sampli ng Date	Sampli ng Date	Sampli ng Date	Samplin g Date	Samplin g Date			Samplin g Date	Samplin g Date	
	4-Jan	4-Jan	1-Feb	1-Feb	1-Mar	1-Mar	2-Mar	2-Mar	6-Apr	6-Apr	3-May	3-May	7-Jun	7-Jun			5-Jul	5-Jul	
	HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg			HCC	Leg	
Caul - B	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr			Clr	Clr	
Caul - B	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr			Clr	Clr	
Caul - H	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr			Clr	Clr	
Caul - S	Clr	Clr	Clr	Clr	Clr	Clr	-	-	Clr	Clr	Clr	Clr	Clr	Clr			Clr	Clr	

2021 Cooling Tower Test Results

RED CELL HCC >200K cfu or Leg > = 10 cfu

CT No	Location	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Sampling Date	Total	Total	Total
		14-Jul	14-Jul	11-Aug	11-Aug	8-Sep	8-Sep	6-Oct	6-Oct	2021	2021	2021
		HCC	Leg	HCC	Leg	HCC	Leg	HCC	Leg	All	+ve HCC	+ve Leg
1	37 - North Ground - Engineering 37	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
5	37 - Engineering 37 Annex	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
6	36 - Roof Area - Engineering 36	-	-	-	-	-	-	-	-	0	0	0
8	30 - Hargrave Library	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
10	28 - Mathematics Building	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
21	23 - Chemistry - S-West Roof	-	-	-	-	-	-	-	-	0	0	0
23	23 - Science N - Chem Roof Area	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
26	18 - Zoology West - Roof Area	-	-	-	-	-	-	-	-	0	0	0
29	17 - Biology - Roof Area	-	-	-	-	-	-	-	-	0	0	0
37	12 - Law School - Roof Area	-	-	-	-	-	-	-	-	0	0	0
43	5 - Krongold Centre - Roof Plant Rm	-	-	-	-	-	-	-	-	8	0	0
51	11 - Menzies South - 9th Fl. Roof, Unit 1	-	-	-	-	-	-	-	-	0	0	0
54	75 - STRIP 1	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
56	11 - Menzies South - 9th Fl. Roof, Unit 2	-	-	-	-	-	-	-	-	0	0	0
57	35 - Building 35 Roof	-	-	-	-	-	-	-	-	0	0	0
58	23 - Chemistry Roof E.	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
59	23 - Chemistry Roof E.	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
31/32	13F - Medicine 13F - Roof Plant Room	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
34/ 35	13D - Medicine 13D - Roof Area	-	-	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
46/ 47	68 - Performing Arts Centre - E Roof	-	-	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
49/ 50	25 - Eastern Science L.T. 25	-	-	-	-	-	-	-	-	8	0	0
52/ 53	75 - STRIP 1	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
60/ 61	76 - STRIP 2 Roof (#60 to E; #61 to W)	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
62/ 63	86 - Green Chemical Futures	Clr	Clr	Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
				Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Samplin g Date	Sampling Date			
				2-Aug	2-Aug	6-Sep	6-Sep	4-Oct	4-Oct			
				HCC	Leg	HCC	Leg	HCC	Leg			
	Caul - B			Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
	Caul - B			Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
	Caul - H			Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
	Caul - S			Clr	Clr	Clr	Clr	Clr	Clr	20	0	0
										376	0	0