

SUMMARY OF COOLING TOWER TESTING STATUS (Clayton)

Building No.	CT	Building	Last Sampling Date	Test	Status
5	43	Krongold Centre S. Roof Plant Room 57 Scenic Bvd			System Empty
12	37	Law School - Roof Area 15 Ancora Imparo Way			System Empty
13D	34/35	Medical 13D South Roof 35 Rainforest Walk	9 July 2025	HCC & Leg	Clear
13F	31/32	Medical 13F Roof Plant Room 26 Innovation Walk	9 July 2025	HCC & Leg	Clear
17	29	Biology - Roof Area 18 Innovation Walk			System Empty
18	26	Zoology West - Roof Area 25 Rainforest Walk			System Empty
23	23	Chemistry East Roof Area 17 Rainforest Walk	9 July 2025	HCC & Leg	Clear
23	58	Chemistry East Roof Area 17 Rainforest Walk			System Empty
23	59	Chemistry East Roof Area 17 Rainforest Walk	9 July 2025	HCC & Leg	Clear
25	49/50	Eastern Science Lecture Theatres 15 Rainforest Walk			System Empty
28	10	Mathematics Building Ground North 9 Rainforest Walk	9 July 2025	HCC & Leg	Clear
30	08	Hargrave-Andrew Library Roof 13 College Walk	9 July 2025	HCC & Leg	Clear
37	05	Engineering 37 South East Roof 17 Alliance Lane	9 July 2025	HCC & Leg	Clear
37	01	North Ground - Engineering 37 17 Alliance Lane	9 July 2025	HCC & Leg	Clear
68	46/47	Performing Arts Centre - East Roof 55 Scenic Bvd	9 July 2025	HCC & Leg	Clear
75	52/53	STRIP 1 Building 75 Roof 15 Innovation Walk	9 July 2025	HCC & Leg	Clear
75	54	STRIP 1 Building 75 Roof 15 Innovation Walk	9 July 2025	HCC & Leg	Clear
76	60/61	STRIP 2 Building 76 Roof 19 Innovation Walk	9 July 2025	HCC & Leg	Clear
86	62/63	Green Chemical Futures 13 Rainforest Walk	9 July 2025	HCC & Leg	Clear

SUMMARY OF COOLING TOWER TESTING STATUS (Caulfield)

Building No.	Building.	Last Sampling Date	Test	Status
502	Building B Caulfield #1	10 July 2025	HCC & Leg	Clear
502	Building B Caulfield #2	10 July 2025	HCC & Leg	Clear
510	Building H Caulfield	10 July 2025	HCC & Leg	Clear
518	Building S Caulfield	10 July 2025	HCC & Leg	Clear

COOLING TOWER TESTING STATUS (750 Collins St)

Building No.	Building.	Last Sampling Date	Test	Status
825	Monash College	14 July 2025	HCC & Leg	Clear

If the status of a cooling tower is defined as 'Not Clear' please contact John Luxford (X53042) before a Roof Access Permit is issued.